OR Air Quality: Is it time to consider adjunctive air cleaning technology?

Barnes, Sue; Twomey, Carolyn; Carrico, Ruth; Murphy, Cathryn; Warye, Kathy

Published in:
AORN Journal

DOI:
[10.1002/aorn.12391](https://doi.org/10.1002/aorn.12391)

Licence:
Other

[Link to output in Bond University research repository.](#)

Recommended citation(APA):

Barnes, S., Twomey, C., Carrico, R., Murphy, C., & Warye, K. (2018). OR Air Quality: Is it time to consider adjunctive air cleaning technology? *AORN Journal*, 108(5), 503-515. <https://doi.org/10.1002/aorn.12391>

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

For more information, or if you believe that this document breaches copyright, please contact the Bond University research repository coordinator.

OR Air Quality: Is It Time to Consider Adjunctive Air Cleaning Technology?

Sue Barnes, BSN, RN, CIC, FAPIC; Carolyn Twomey, BSN, RN; Ruth Carrico, PhD, DNP, FNP-C, FSHEA, CIC; Cathryn Murphy, PhD, FSHEA, CIC; Kathy Warye, BA

ABSTRACT

Patients undergoing surgery may be at risk for infection from airborne particles such as dust, skin scales, respiratory aerosols, and hair fibers emanating from multiple sources in the OR, including personnel, heater-cooler devices and surgical smoke. This risk is increased in surgical patients undergoing procedures involving implanted devices. Surgical personnel are also at risk from exposure to surgical smoke which can contain viable viral particles including human papillomavirus virus. Air quality in the OR is improved by engineering controls (e.g., maintaining positive pressure); and, during the past decade there has been innovation in the field of adjunctive technology designed to improve OR air quality including built in UV disinfection and mobile UV disinfection plus high efficiency particulate air filtration (HEPA). Some of these technologies additionally provide continuous monitoring of circulating air particle counts. Further research regarding the risk reduction benefits of these adjunctive air-cleaning technologies in operating rooms is warranted.

Key words: *surgical smoke, heater-cooler units, air cleaning technology, surgical plume, Mycobacterium chimaera.*

BACKGROUND

Air in the OR may contain contaminants in the form of surgical smoke (also called surgical plume) and other bacteria-laden particles (e.g., dust, skin squames) that may create potential health hazards for surgical team members and patients.^{1,2} When a surgeon uses an electrosurgical unit or a laser for thermal destruction of tissue, it generates surgical smoke. Surgical smoke can contain carbon monoxide, viral and bacterial fragments, as well as carcinogenic and mutagenic particles that can create health risks for surgical team members.³⁻⁵

The risk of patient infection from contaminated air is greatest when the procedure involves an implant such as total joint arthroplasty.⁶ In recent years, there have been reports of OR air contamination with *Mycobacterium chimaera* from the exhaust of heater-cooler units, which has resulted in surgical infections and patient death, underscoring the serious risks associated with contaminated OR air.⁷

Currently in the United States (US), approaches to ensuring high quality air in ORs are limited to implementing engineering controls for maintaining air pressure (i.e., positive in relation to adjacent areas), velocity (i.e., a minimum of 20 air changes per hour), temperature (i.e., between 68° F and 75° F [20° C and 24° C]), humidity (i.e., between 20% and 60%) and air filtration.⁸⁻¹⁰ Air quality standards that include limits for the number of bacteria and specific particles have not been established for US ORs though they have been established for US compounding pharmacies,¹¹ and for European ORs.¹² Progress, however, has been made in adjunctive technology designed to improve the quality of OR air. This includes ultraviolet (UV) disinfection systems built into the OR, as well as mobile devices combining UV disinfection and HEPA filtration.¹³⁻¹⁸

SURGICAL SMOKE

Peer reviewed reports have described adverse health outcomes for the surgical team and patients caused by exposure to surgical smoke, including human papillomavirus (HPV) infection, cancer, and bacterial infection.^{19,20} The US Occupational Safety and Health Administration (OSHA) estimates that each year in the US 500,000 surgeons and perioperative health care workers including RNs and surgical technologists, perform procedures that generate laser or electrosurgical smoke.²¹ In 1996, the National Institute of Occupational Safety and Health (NIOSH) warned of “toxic gases and vapors”, and various health risks including mutagenic threats present in surgical smoke.^{22(p1)}

Smoke from laser and electrosurgery is caused by the fast heating of cells that creates pressure, and the subsequent release of cell membranes and contents, as well as surrounding structures, into the OR environment. The type and amount of tissue being cauterized as well as the environmental conditions affect the materials that are released during laser and electrosurgery. Generally, surgical smoke is composed of 95% steam and 5% solid particulate matter.²³

When a laser is used, the content of the smoke is affected by the pulse duration and the energy application.²⁴ The average size of particles contained in laser smoke is 0.3 micrometers compared with an average particle size of less than 0.1 micrometer contained in electrosurgery smoke.²⁴ These processes of cauterization of living skin and subcutaneous tissue may release chemical compounds into the OR air that include aromatic hydrocarbons (e.g., cresol, phenol, benzene, toluene, xylene), aldehydes (e.g., formaldehyde, acetaldehyde, acrolein), hydrocyanic acid, carbon monoxide, and nitrile compounds.²⁴ Some of these compounds are toxic and/or carcinogenic.²⁴ For example, if acrylonitrile (a nitrile compound that forms hydrocyanic acid)

penetrates the skin and lungs of an individual it can cause nausea and vomiting. Experts have reported that it can also increase the risk of myocardial infarction.²⁵ Similarly, exposure to benzene found in surgical smoke can cause headaches and nausea.²⁵ Baggish and Elbakry²⁶ reported lung effects including congestive interstitial pneumonia, bronchiolitis, and emphysema in rats exposed to laser smoke. Tomita et al²⁷ estimated that exposure to surgical smoke generated by laser cautery of one gram of tissue is comparable to smoking three cigarettes, while burning the same amount of tissue during electrosurgery is comparable to smoking six cigarettes.

Studies have demonstrated that surgical masks worn by surgical team members do not provide adequate protection from surgical smoke.²⁸ The most effective exposure prevention precaution for surgical team members is using sufficient smoke evacuation systems for procedures involving laser or electrosurgery. The efficacy of smoke capture is affected by the smoke evacuator flow rate, distance of the evacuator nozzle to the surgical site, tubing size, and amount of smoke generated.²⁸ According to the AORN Guideline for Surgical Smoke Safety, “the capture device (e.g., wand, tubing) of a smoke evacuation system should be positioned as close to the surgical site as necessary to effectively collect all traces of surgical smoke.”^{28(p493)}

Surgical Smoke and HPV

The smoke from laser and electrosurgery can contain infectious viruses such as the HIV, hepatitis B, and various types of the human papillomavirus (HPV).²⁹ The true risk of HPV transmission from surgical smoke generated during laser or electrosurgery procedures continues to be debated.²⁹⁻³³ Garden et al²⁹ captured laser smoke after carbon dioxide laser treatment and analyzed the smoke for viral DNA content. The researchers found that intact viral DNA was aerosolized during laser treatment; however, they did not demonstrate that the viruses were

infectious. In a similar study to determine if HPV DNA was present in laser smoke, Hughes et al³⁰ detected no HPV DNA during five procedures involving ablation of HPV-positive warts. In another study, Garden et al³¹ collected laser smoke containing papillomavirus DNA and reinoculated the collected smoke into the skin of calves. The researchers found that tumors containing the same virus present in the laser smoke developed at all of the inoculated sites. They concluded that laser smoke could transmit disease.

Studies have reported that surgical team members maybe at risk of developing HPV when inhaling surgical smoke containing virus particles during condyloma ablation.^{32,33} In one report, a laser surgeon developed laryngeal papillomatosis, a condition in which benign tumors (i.e., papilloma) caused by the HPV virus develop along the aerodigestive tract. Tissue samples from the surgeon's tumors contained HPV DNA. The surgeon reported having performed laser therapy on patients with anogenital condylomas which are known to harbor HPV.³² Another report of occupational HPV infection involved a gynecological OR nurse, who assisted in numerous electrosurgical and laser excisions of anogenital condylomas, and subsequently developed recurrent laryngeal papillomatosis. The authors concluded there was a high probability of association between the reported occupational exposure of the nurse and the development of her laryngeal papillomatosis.³³

Surgical Smoke and Cancer

Rioux et al³⁴ reported two cases of cancer in laser surgeons. The first case involved a 53-year-old male gynecologist who developed HPV 16-positive tonsillar squamous cell carcinoma. The physician had no risk factors for cancer or HPV except long term occupational exposure to laser smoke during more than 3,000 laser ablations and loop electrosurgical excision procedures over

20 years of practice. The second case involved another male gynecologist with a 30-year history of performing laser ablation and loop electrosurgical excision procedures, who developed HPV 16-positive cancer of the tongue.

To determine whether viable malignant cancer cells are present in surgical smoke, Fletcher et al³⁵ cauterized mouse melanoma cells, and assessed cell viability immediately and 7 days after collection. The researchers found that the surgical smoke contained viable cancer cells for up to one week after collection. This finding supported the researchers' hypothesis that port site metastasis after laparoscopic colon resection could be the result of seeding malignant cells contained in surgical smoke. These findings also support the argument that surgical smoke creates a risk for perioperative personnel who potentially could inhale viable tumor debris in surgical smoke.

BACTERIA IN OR AIR

There are reports of bacterial transmission risk via surgical smoke. Schultz³ used an experimental model of porcine tissue embedded with *Serratia marcescens* to determine the extent of viable bacteria present in surgical smoke. The researchers found that the plume from blended current electrosurgery (where the surgeon performs cutting and coagulation functions at the same time) contained viable bacteria, whereas the plume from coagulation electrosurgery and lasers did not. In a related study,

Capizzi et al³⁶ used an air filter to quantitatively test for pathogens in laser smoke during laser resurfacing. The researchers found viable bacteria including coagulase-negative staphylococcus, *Corynebacterium*, and *Neisseria*. The researchers theorized that if the patient were colonized with pathogenic bacteria such as *Staphylococcus aureus*, the surgical team could

be exposed and, based on the air circulation patterns in the facility, individuals in adjacent rooms could also be exposed. For example, if a patient undergoes ulcer debridement under moist conditions it can lead to significant air contamination with pathogens such as *S aureus* and *Pseudomonas aeruginosa*, which have been reported to remain detectable in air for some time after aerosolization. This is a risk in any procedure where a laser or electrosurgery is used in moist and pathogen-dense tissue if the pathogen is not completely eradicated. The level of risk depends on the type and concentration of the pathogen and the surgical team's use of appropriate personal protective equipment.³⁷

Circulating airborne bacteria-laden particles from equipment with contaminated air exhaust such as heater-cooler devices, as well as hair, dust, skin squames, or respiratory aerosols from surgical team members can create a risk of infection for patients, especially during procedures involving an implant.^{38,39} Introducing a foreign body into a patient can reduce the number of organisms necessary to cause an infection by a factor of 100,000. This is because the human body's primary immunologic response focuses on the implant as a foreign body, instead of focusing on the microorganisms contaminating the surgical wound.⁴⁰ The contaminating microorganisms are thus able to multiply, form a biofilm, and cause an infection.⁴⁰

Outbreaks of invasive *M. chimaera* surgical infections associated with heater-cooler devices used during cardiac surgery procedures have affected patients in several countries since 2015.⁷ Investigations of these outbreaks clearly demonstrate that the surgical infections, with associated morbidity and in some cases mortality, were transmitted to surgical patients by OR air contaminated with exhaust from the heater-cooler devices.⁷

Foot traffic and door openings disrupt the positive air pressure in the OR and may result in the settling of contaminating microorganisms attached to airborne particles (e.g., dust, lint) in

the open surgical incision or on the surgical implant, surgical instruments, or surgical team members' gloves.⁴⁰⁻⁴⁴ Lynch et al⁴⁴ observed and recorded behaviors of perioperative personnel in the OR. The researchers collected information that included the number of people entering and leaving the OR, their positions, and their reason for leaving or entering the room. The researchers found there were more than 3,000 door openings over the course of 28 procedures. The number of door openings ranged from 19 to 50 per procedure. The number of door openings increased as the length of the case increased, and was also associated with the number of people in the OR.

CONTROLLING OR AIR QUALITY

The engineering controls implemented to limit circulating particles and bacteria in US ORs are defined by the Facility Guidelines Institute (FGI)^{8,9} and the American Society of Heating, Refrigeration, and Air-Conditioning Engineers (ASHRAE).¹⁰ These guidelines are supported by the Centers for Disease Control and Prevention (CDC),⁴⁵ AORN,⁴⁶ and the Association for the Advancement of Medical Instrumentation (AAMI).⁴⁷ The engineering controls include maintaining air pressure (i.e., positive pressure in relation to adjacent areas), velocity (i.e., a minimum of 20 air changes per hour, four of which are from outside air), temperature (i.e., between 68° F and 75° F [20° C and 24° C]), humidity (i.e., between 20% and 60%), and using sequential air filtration.^{8,9,10,45-47}

Additionally, FGI recommends using sequential HEPA filters for ORs with a minimum efficiency reporting value (MERV) rating of 7 (designed to capture particles 10 to 3 micrometers in size) and 14 (designed to capture particles from 1 micrometer to 0.3 micrometers in size).^{8,9} The MERV is a measurement scale used to rate air filters based on the size of a particle they are able to filter out of the air. The higher the MERV rating, the more effective the filter.^{8,9}

All of these guidelines for improving air quality in ORs are based on consensus of professional expert opinion, versus being mandated by law or regulation.

ADJUNCTIVE OR AIR CLEANING TECHNOLOGY

During the past decade there have been innovations in adjunctive technology for improving OR air quality. Some of these are UV disinfection systems designed to be built in to the HVAC or lighting systems in an OR. There are also mobile units that provide both HEPA filtration and UV-C disinfection for all air in the OR for the duration of the procedure. Combining HEPA plus UV disinfection of air in a mobile device provides benefits including:

- filtering particulates from the air including those associated with surgical smoke,
- inactivating microorganisms (disinfection) using UV-C light,
- requiring a minimum of space (i.e., 400 ft²; 122 m²) and operating successfully when located a distance (i.e., 13 ft; 4 m) from the procedure,
- running continuously during a procedure without an operator present,
- not creating any air turbulence or disruption of the OR air balance.¹⁴⁻¹⁸

Several conference reports¹⁴⁻¹⁷ and one laboratory pilot study¹⁸ have described the efficacy and benefits of OR air cleaning technology using HEPA filtration plus UV-C disinfection. At the 2017 Australasian College for Infection Prevention and Control annual conference, Walsh¹⁶ reported that air filtration and disinfection units combining HEPA filtration and UV-C disinfection technologies significantly reduced the total and viable particle counts in a highly-controlled OR setting, and suggested that this may reduce the potential for patient infection. Ongoing innovation and refinement of air cleaning technologies as well as ongoing research exploring all risks and benefits associated with the technology is prudent given the risk of patient

infection associated with contaminated OR air and the health risks to surgical team members associated with exposure to surgical smoke.

DISCUSSION

In addition to adhering to engineering controls for maintaining air quality in ORs AORN recommends implementing specific perioperative practices to reduce environmental and air contamination. These practices include minimizing foot traffic and the number of door openings during surgical procedures,⁴⁸ clipping patient hair in a location outside of the OR before bringing the patient to the OR,⁴⁹ and having surgical team members wear long sleeves and to cover all hair.⁵⁰

AORN and NIOSH support the use of smoke evacuators to eliminate surgical smoke and minimize the associated exposure risks for surgical team members.^{22,28} Using smoke evacuators, however, is not mandatory and compliance is not universal.^{22,51,52} Smoke evacuators may be inconsistently used in ORs for several reasons including the

- cost of tubing and filters,
- need to position the evacuator wand as close as possible to the incision,
- time required to set up, and
- noise from the evacuator.

When the evacuator wand is placed close to the surgical site, it could get in the way and interfere with the surgical procedure. As well, evacuators create negative pressure over the surgical site. Negative air pressure in an isolation room is designed to contain airborne contaminants within the room. In a similar manner, the negative pressure created by a smoke evacuation system could theoretically pull any nearby circulating bacteria-laden particles toward the incision.⁵³

Beyond supporting established engineering controls for air filtration, air pressure, velocity, temperature, and relative humidity, professional organizations have not provided additional recommendations, and regulatory agencies have not introduced regulations for mandatory testing of the quality of OR air. Mandatory air quality standards (i.e., limits for specific particle counts and bacteria levels) are in effect for US compounding pharmacies¹¹ and European ORs,¹² but not for US ORs.¹¹ The US Pharmacopeia General Chapter <797> Pharmaceutical Compounding—Sterile Preparations¹¹ requires compounding pharmacies to comply with the International Organization for Standardization class 5 standards for cleanroom air quality.⁵⁴ A class 5 cleanroom is limited to at most 100,000 particles (0.1 micrometers in size) per cubic meter of air.⁵³ Both compounding pharmacies and ORs implement aseptic practices; however, it could be argued that the standard for air quality in an OR should be *more* stringent than the standard for a compounding pharmacy, because there are many more factors causing air contamination (e.g., heater-cooler devices, skin squames and hair shed from surgical team members, bioaerosols, bacteria-laden air particles disseminated via foot traffic and door openings during procedures).

Without a regulatory mandate for measuring air quality and achieving specific air quality standards in US ORs, there remains a risk of infection for patients, especially those patients undergoing surgical procedures involving implants.^{6,40} Currently, many surgical disciplines engage in the implantation of biomedical devices. In the US, approximately 1.2 million joint arthroplasty procedures are performed annually.⁵⁵ That number is expected to increase to 3.8 million by 2030.⁵⁵ The amount of patient suffering and the associated health care cost for each infection is tremendous.⁵⁵ Recent reports estimate that the range of associated costs for a prosthetic joint infection is between \$100,000 and \$400,000.⁵⁶

CONCLUSION

The contamination of air in the OR presents a potential infection risk for surgical patients. Surgical team members may also be at risk from air contaminated with surgical smoke. Recent innovations have made air cleaning technology available for ORs and are designed to work adjunctively with existing engineering controls. Early evidence of air cleaning technology efficacy is compelling, though continuing refinement of the technology and additional research that focuses on the benefits of improving OR air quality for patients and surgical team members is warranted.

REFERENCES

1. Dikes CN. Is it safe to allow smoke in our operating room? *Today's Surg Nurse*. 1999;21(2):15–21.
2. Alp E, Bijl D, Bleichrodt RP, Hansson B, Voss A. Surgical smoke and infection control. *J Hosp Infect*. 2006;62(1):1-5.
3. Schultz L. Can efficient smoke evacuation limit aerosolization of bacteria? *AORN J*. 2015;102(1):7-14.
4. Bree K, Barnhill S, Rundell W. The dangers of electrosurgical smoke to operating room personnel: a review. *Workplace Health Saf*. 2017;65(11):517-526.
5. Schultz L. An analysis of surgical smoke plume components, capture, and evacuation. *AORN J*. 2014;99(2):289-298.
6. Edmiston CE Jr, Sinski S, Seabrook GR, Simons D, Goheen MP. Airborne particulates in the OR environment. *AORN J*. 1999;69(6):1169-1179.

7. Sommerstein R, Schreiber PW, Diekema DJ, et al. *Mycobacterium chimaera* outbreak associated with heater-cooler devices: piecing the puzzle together. *Infect Control Hosp Epidemiol*. 2017;38(1):103-108.
8. Facility Guidelines Institute. *Guidelines for Design and Construction of Hospitals*. Chicago, IL: American Hospital Association; 2018.
9. Facilities Guidelines Institute. *Guidelines for Design and Construction of Outpatient Facilities*. Chicago, IL; American Hospital Association; 2018.
10. ANSI/ASHRAE/ASHE Addendum h to ANSI/ASHRAE/ASHE Standard 170-2013: *Ventilation of Health Care Facilities*. Atlanta, GA: American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc; 2016.

https://www.ashrae.org/File%20Library/Technical%20Resources/Standards%20and%20Guidelines/Standards%20Addenda/170-2013/170_2013_h_20160523.pdf. Accessed July 2, 2018.
11. United States Pharmacopeia Convention. Committee of Revision. Pharmaceutical compounding—sterile preparations. In: *The United States Pharmacopeia*. 27th ed. Rockville, MD: United States Pharmacopeial Convention, Inc; 2009:318-354.
12. Nastase I, Croitoru C, Vartires A, Tataranu L. Indoor environmental quality in operating rooms: an European standards review with regard to Romanian guidelines. *Energy Procedia*. 2016;85:375-382.
13. Charkowska A. Ensuring cleanliness in operating theatres. *Int J Occup Saf Ergon*. 2008;14(4):447-453.
14. Kirschman D, Eachempati S. Airborne bacteria in the operating room can be reduced by HEPA/Ultraviolet air recirculation system (HUAIRS). Presented at: The 37th Annual Meeting of the Surgical Infection Society; May 2-5, 2017; St. Louis, MO.

15. Walsh W. Controlling airborne particles during surgical procedures using a novel device.
Presented at: ACIPC Conference 2017; November 20-22, 2017; Canberra, Australia.
<http://2017.ACIPCconference.com.au/3446>. Accessed July 15, 2018.
16. Davies GS, Bradford N, Oliver R, Walsh WR. The effects of a novel decontamination-recirculating system in reducing airborne particulate: a laboratory-based study. Presented at: The 36th Annual Meeting of the European Bone & Joint Infection Society; September 7-9, 2017; Nantes, France.
17. Bischoff W. Impact of a novel mobile air purification system on the bacterial air burden during routine care. Presented at: SHEA Spring 2018 Conference; April 18-20, 2018; Portland, OR.
18. Curtis GL, Faour M, Jawad M, Klika AK, Barsoum WK, Higuera CA. Reduction of particles in operating room using ultraviolet air disinfection and recirculation units. *J Arthroplasty*. 2018;33(7S):S196-S200.
19. Fletcher JN, Mew D, DesCôteaux JG. Dissemination of melanoma cells within electrocautery plume. *Am J Surg*. 1999;178(1):57-59.
20. Steege AL, Boiano JM, Sweeney MH. Secondhand smoke in the operating room? precautionary practices lacking for surgical smoke. *Am J Ind Med*. 2016;59(11):1020–1031.
21. Laser/electrosurgery plume. Occupational Safety and Health Administration, US Department of Labor. <https://www.osha.gov/SLTC/laserelectrosurgeryplume/index.html>. Accessed June 26, 2018.
22. Control of smoke from laser/electric surgical procedures (DHHS [NIOSH] Pub No 96-128). National Institute for Occupational Safety and Health, Department of Health and Human

Services. <http://www.cdc.gov/niosh/docs/hazardcontrol/hc11.html>. Updated June 6, 2014. Accessed June 26, 2018.

23. Albrecht H, et al. Safety technology in laser medicine. *Journal of the German Society of Dermatology. Institut für Medizinische/Technische Physik und Lasermedizin*. 1996;135-134.
24. Barrett WL, Garber SM. Surgical smoke: a review of the literature. Is this just a lot of hot air? *Surg Endosc*. 2003;17(6):979-987.
25. Moot AR, Ledingham KM, Wilson PF, et al. Composition of volatile organic compounds in diathermy plume as detected by selected ion flow tube mass spectrometry. *ANZ J Surg*. 2007;77(1-2):20-23.
26. Baggish MS, Elbakry M. The effects of laser smoke on the lungs of rats. *Am J Obstet Gynecol*. 1987;156(5):1260-1265.
27. Tomita Y, Mihashi S, Nagata K, et al. Mutagenicity of smoke condensates induced by CO₂-laser irradiation and electrocauterization. *Mutat Res*. 1981;89(2):145-149.
28. Guideline for surgical smoke safety. In: *Guidelines for Perioperative Practice*. Denver, CO: AORN, Inc; 2018:469-497.
29. Garden JM, O'Banion MK, Shelnitz LS, et al. Papillomavirus in the vapor of carbon dioxide laser treated verrucae. *JAMA*. 1988;259(8):1199-1202.
30. Hughes PS, Hughes AP. Absence of human papillomavirus DNA in the plume of erbium: YAG laser-treated warts. *J Am Acad Dermatol*. 1998;38(3):426-428.
31. Garden JM, O'Banion MK, Bakus AD, Olson C. Viral disease transmitted by laser-generated plume (aerosol). *Arch Dermatol*. 2002;138(10):1303-1307.
32. Hallmo P, Naess O. Laryngeal papillomatosis with human papillomavirus DNA contracted by a laser surgeon. *Eur Arch Otorhinolaryngol*. 1991;248(7):425-427.

33. Calero L, Brusis T. Laryngeal papillomatosis—first recognition in Germany as an occupational disease in an operating room nurse. [in German] *Laryngorhinootologie*. 2003;82(11):790-793.
34. Rioux M, Garland A, Webster D, Reardon E. HPV positive tonsillar cancer in two laser surgeons: case reports. *J Otolaryngol Head Neck Surg*. 2013;42:54.
35. Fletcher JN, Mew D, DesCôteaux JG. Dissemination of melanoma cells within electrocautery plume. *Am J Surg*. 1999;178(1):57-59.
36. Capizzi PJ, Clay RP, Battey MJ. Microbiologic activity in laser resurfacing plume and debris. *Lasers Surg Med*. 1998;23(3):172-174.
37. Däschlein G, Lehnert W, Arnold A, Haase H, Jünger M. Hygienic safety of a new hydrodynamic wound debridement system. *Dermatol Surg*. 2010;36(9):1426-1438.
38. Tammelin A, Ljungqvist B, Reinmüller B. Comparison of three distinct surgical clothing systems for protection from air-borne bacteria: a prospective observational study. *Patient Saf Surg*. 2012;6(1):23.
39. van Ingen J, Kohl TA, Kranzer K, et al. Global outbreak of severe *Mycobacterium chimaera* disease after cardiac surgery: a molecular epidemiological study. *Lancet Infect Dis*. 2017;17(10):1033-1041.
40. Zimmerli W, Trampuz A, Ochsner PE. Prosthetic-joint infections. *N Engl J Med*. 2004;351(16):1645-1654.
41. Owers KL, James E, Bannister GC. Source of bacterial shedding in laminar flow theatres. *J Hosp Infect*. 2004;58(3):230-232.

42. Dalstrom DJ, Venkatarayappa I, Manternach AL, Palcic MS, Heyse BA, Prayson MJ. Time-dependent contamination of opened sterile operating-room trays. *J Bone Joint Surg Am.* 2008;90(5):1022-1025.
43. Memarzadeh F, Xu W. Role of air changes per hour (ACH) in possible transmission of airborne infections. *Build Simul.* 2012;5(1):15-28.
44. Lynch RJ, Englesbe MJ, Sturm L, et al. Measurement of foot traffic in the operating room: implications for infection control. *Am J Med Qual.* 2009;24(1):45-52.
45. Sehulster L, Chinn RY, CDC, HICPAC. Guidelines for environmental infection control in health-care facilities. Recommendations of the CDC and the Healthcare Infection Control Practices Advisory Committee (HICPAC). *MMWR Recomm Rep.* 2003;52(RR-10):1-42.
46. Guideline for a safe environment of care, part 2. In: *Guidelines for Perioperative Practice.* Denver, CO: AORN, Inc; 2018:269-293.
47. Association for the Advancement of Medical Instrumentation. ANSI/AAMI ST79:2017—*Comprehensive Guide to Steam Sterilization and Sterility Assurance in Health Care Facilities.* Arlington, VA: Association for the Advancement of Medical Instrumentation; 2017:19.
48. Guideline for sterile technique. In: *Guidelines for Perioperative Practice.* Denver, CO: AORN, Inc; 2018:75-103.
49. Guideline for preoperative patient skin antisepsis. In: *Guidelines for Perioperative Practice.* Denver, CO: AORN, Inc; 2018:51-74.
50. Guideline for surgical attire. In: *Guidelines for Perioperative Practice.* Denver, CO: AORN, Inc; 2018:105-127.
51. AORN. Management of Surgical Smoke Tool Kit. <https://www.aorn.org/guidelines/clinical->

- resources/tool-kits/management-of-surgical-smoke-tool-kit. Accessed June 26, 2018.
52. Berríos-Torres SI, Umscheid CA, Bratzler DW, et al. Centers for Disease Control and Prevention Guideline for the Prevention of Surgical Site Infection, 2017. *JAMA Surg*. 2017;152(8):784–791.
53. Barrick JR, Holdaway RG. *Mechanical Systems Handbook for Health Care Facilities*. Chicago, IL: The American Society for Healthcare Engineering of the American Hospital Association; 2014.
54. American National Standards Institute/Institute of Environmental Sciences and Technology/International Organization for Standardization. ANSI/IEST 14644-1:2015—*Classification of air cleanliness by particle concentration*. Schaumburg, IL: Institute of Environmental Sciences and Technology; 2015.
55. Kurtz SM, Lau E, Watson H, Schmier JK, Parvizi J. Economic burden of periprosthetic joint infection in the United States. *J Arthroplasty*. 2012;27(8 suppl):61-65.
56. Parisi TJ, Konopka JF, Bedair HS. What is the long-term economic societal effect of periprosthetic infections after THA? a Markov analysis. *Clin Orthop Relat Res*. 2017;475(7):1891-1900.

Sue Barnes, BSN, RN, CIC, FAPIC, is an independent clinical consultant in infection prevention and control in San Mateo, CA. *As a consultant to companies that may be affected by the research reported in the paper, Ms Barnes has disclosed an affiliation that could be perceived as posing a potential conflict of interest for the publication of this article.*

Carolyn Twomey, BSN, RN, is the vice president of Clinical, Research, and Regulatory at the IrriMax Corporation, Henrico, VA. *As an employee of a company that sells products to companies that may be affected by the research reported in the paper, Ms Twomey has disclosed an affiliation that could be perceived as posing a potential conflict of interest for the publication of this article.*

Ruth Carrico, PhD, FNP-C, FSHEA, CIC, is an associate professor in the Division of Infectious Diseases at the University of Louisville in Louisville, KY. *Ms Carrico has no declared affiliation that could be perceived as posing a potential conflict of interest for the publication of this article.*

Cathryn Murphy, PhD, FSHEA, CIC, is an adjunct associate professor of Health, Sciences and Medicine at Bond University, Robina, Queensland, Australia; and the chief executive officer and creative director, Infection Control Plus Pty Ltd, West Burleigh, Queensland, Australia. *As the employee of a company that provides consulting services to companies that may be affected by research in this article, Dr Murphy has disclosed an affiliation that represents a potential conflict of interest.*

Kathy Warye, BA, is the founder of Infection Prevention Partners, Washington, DC. *As the founder of a company that provides services to companies that may be affected by the research reported in the paper, Ms Warye has disclosed an affiliation that could be perceived as posing a potential conflict of interest for the publication of this article.*

Key Takeaways

- Exposure to surgical smoke can lead to adverse health outcomes for the patient and surgical team that include respiratory irritation, transmission of HPV, skin cancer, and bacterial infection.
- AORN and the National Institute for Occupational Safety and Health support the use of smoke evacuators to eliminate surgical smoke and minimize the risk of exposure for surgical team members.
- Circulating airborne bacteria-laden particles from heater-cooler units, as well as hair, dust, skin squames or respiratory aerosols from surgical team members can create a risk for patient infection, especially during procedures involving an implant.
- Currently, air quality in US ORs is maintained by implementing engineering controls that include sequential air filtration and maintaining positive air pressure, at least 20 air changes per hour, relative humidity between 20% and 60%, and temperature between 68° F and 75° F (20° C and 24° C).
- Mobile adjunctive air cleaning technology comprising HEPA filtration and UV-C disinfection may reduce environmental and air contamination, when implemented in addition to existing engineering controls.